

Number 23-003131-PR01 (NW-AD1-0203-en-01)

Owner Kontinent-Group LLC
Nebesnoji Sotni Str.
18002 Cherkasy
Ukraine






Product Single leaf tilt and turn window fixed sublight

Designation System: PVC Framex -80
Shipping name: KG

Details Manufacturer Kontinent-Group LLC, - Cherkasy;
Material Polyvinylchloride unplasticized (uPVC) white;
Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1100 mm x 2700 mm

Special features

Result **)

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2020-08	Mechanical properties according to EN 13115:2020-08
				
4	C4/B4	E1200	1	4

***) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
13.06.2024



Robert Kolačný, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Maximilian Denk
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2008+A2:2016-09
) and corresponding national versions (e.g. DIN EN)

Test report: 23-003131-PR01 PB-AD1-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-guidance sheet "conditions and guidance for the use of ift test documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-aerueft
ID: 9C8-AC199

